



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10263-48-5621
State Number
27279

EQUIPMENT INSPECTED

State Number: 27279	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 130
Landings: 2	Installed: 09/20/2010	Rope Size:
Volts: 208	Complied: 09/20/2010	Entrances: 1

OWNER

CITY OF SOUTHPORT
113 W MOORE STREET
SOUTHPORT, NC, 28461

OCCUPANT

SOUTHPORT FIRE STATION
1011 N HOWE STREET
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date 09/20/2010	Type Inspection New	Certificate Status Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	------------------------	------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: BOB [TKE]

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CITY OF SOUTHPORT
113 W MOORE STREET
SOUTHPORT, NC, 28461