N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10267-48-0477
State Number
H1766

EQUIPMENT INSPECTED

State Number: **H1766**
Capacity: 750
Landings: 2
Volts: 115

Type of Unit: Hand Lift
Manuf: ACC
Installed: 06/26/2006
Complied: 06/26/2006

Floor to Floor: 1 to 2
Speed: 18
Rope Size: 0
Entrances: 2

OWNER
COASTAL COMMUNITY BEACH CLUB
471 OCEAN BLVD
HOLDEN BEACH, NC, 28462

OCCUPANT
COASTAL COMMUNITY BEACH CLUB
471 OCEAN BLVD
HOLDEN BEACH, NC, 28462

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
09/24/2010	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.13.1[k] Properly maintain door closers, where required. REPAIR 1ST FL DOOR TO CLOSE ON ITS OWN.

Items must be corrected by: 10/24/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
COASTAL COMMUNITY BEACH CLUB
471 OCEAN BLVD
HOLDEN BEACH, NC, 28462