N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10292-7-3695
State Number
14783

EQUIPMENT INSPECTED

State Number: **14783**
Capacity: 2500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 09/28/1992
Complied: 09/28/1992

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
MOUNTAIN VILLAGE APTS
200 LUTHER ROAD
JEFFERSON, NC, 28640

OCCUPANT
MOUNTAIN VILLAGE APTS
200 LUTHER RD
JEFFERSON, NC, 28640

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
10/19/2010	Routine	Re-issued	7 - Hoffman	ASHE

5

VIOLATIONS

NONE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: CRYSTAL WOODS 336-246-9040 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
MOUNTAIN VILLAGE APTS
200 LUTHER ROAD
JEFFERSON, NC, 28640