



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10298-24-3112
State Number
22572

EQUIPMENT INSPECTED

State Number: 22572	Type of Unit: Passenger	Floor to Floor: 1 to 9
Capacity: 2500	Manuf: OTIS	Speed: 200
Landings: 9	Installed: 04/26/2005	Rope Size: .
Volts: 208	Complied: 09/14/2005	Entrances: 1

OWNER

21 BATTERY PARK L.L.C.
C/O IPM CORP./ ATTN: HEATHER MARTIN
ARDEN, NC, 28704-0580

OCCUPANT

21 BATTERY PARK CONDOMINIUM
21 BATTERY PARK
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 10/25/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

- 2.14.7.4 Protect the car lights from accidental contact. Sleeves missing on car lighting and no end caps. Must be sleeved where no glass is inside elevator. 2ND NOTICE !!!!!!!!!!!!!!!
- 8.6.4.1.3 Provide proper operation of the belt monitor or replace the belts. The monitor is showing defects!!

Items must be corrected by: 11/24/2010

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Heather / IPM Corp. / 828-650-6875

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

21 BATTERY PARK L.L.C.
C/O IPM CORP./ ATTN: HEATHER MARTIN
ARDEN, NC, 28704-0580