



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10298-24-5597
State Number
25984

EQUIPMENT INSPECTED

State Number: 25984	Type of Unit: Passenger	Floor to Floor: 1 to 11
Capacity: 3500	Manuf: SCHINDLER	Speed: 350
Landings: 11	Installed: 09/15/2008	Rope Size: 11mm
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
60 NORTH MARKET ST. CONDO ASSOCIATION	60 NORTH MARKET STREET	
C/O IPM CORP/ ATTN: HEATHER MARTIN	60 N MARKET STREET	
ARDEN, NC, 28704-0580	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 10/25/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4.13.1[] Properly maintain door restrictors, where required. Latch on header. 2 ND NOTICE!!!!!!!!!!!!!!

Items must be corrected by: 11/24/2010

Elevator Name: ELEVATOR # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Heather Martin / IPM Corp/828-650-6875

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

60 NORTH MARKET ST. CONDO ASSOCIATION
C/O IPM CORP/ ATTN: HEATHER MARTIN
ARDEN, NC, 28704-0580