



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10312-48-0093
State Number
25220

EQUIPMENT INSPECTED

State Number: 25220	Type of Unit: Passenger	Floor to Floor: 1 to 5
Capacity: 3500	Manuf: OTIS	Speed: 150
Landings: 5	Installed: 05/29/2008	Rope Size:
Volts: 208	Complied: 05/29/2008	Entrances: 1
OWNER	OCCUPANT	
CAMS	REGENCY CONDOS BLDG 2	
4705 SOUTHPORT-SUPPLY RD. UNIT 106	915 SHORELINE DR. W	
SOUTHPORT, NC, 28461	SUNSET BEACH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 11/08/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.26.12	Provide Braille where needed. 4TH. FL.
8.6.8.9	Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. 4TH. FL.

Items must be corrected by: 11/28/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAMS
4705 SOUTHPORT-SUPPLY RD. UNIT 106
SOUTHPORT, NC, 28461