



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10313-24-0039
State Number
23379

EQUIPMENT INSPECTED

State Number: 23379	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: SCHINDLER	Speed: 100
Landings: 3	Installed: 12/08/2005	Rope Size:
Volts: 208	Complied: 12/08/2005	Entrances: 1

OWNER

ASHEVILLE CHAMBER OF COMMERCE
36 MONTFORD AVE
ASHEVILLE, NC, 28801

OCCUPANT

ASHEVILLE CHAMBER OF COMMERCE
36 MONTFORD AVE
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 11/09/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.10.1 Update the monthly fire service log. Last date 9/10

Items must be corrected by: 12/09/2010

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Rojealous Rush / 828-258-6119

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ASHEVILLE CHAMBER OF COMMERCE
36 MONTFORD AVE
ASHEVILLE, NC, 28801