



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10313-48-4796
State Number
21810

EQUIPMENT INSPECTED

State Number: 21810	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 07/23/2003	Rope Size: 0
Volts: 208	Complied: 07/30/2003	Entrances: 1
OWNER	OCCUPANT	
SOUTHPORT BAPTIST CHURCH	SOUTHPORT BAPTIST CHURCH	
PO BOX 10009	200 N HOWE STREET	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28416	

INSPECTION INFORMATION

Inspection Date 11/09/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: GALE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SOUTHPORT BAPTIST CHURCH
PO BOX 10009
SOUTHPORT, NC, 28461