N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10326-48-0278
State Number
15342

EQUIPMENT INSPECTED

State Number: **15342**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 03/09/1994
Complied: 03/15/1994

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
PRESBYTERY OF COASTAL CAROLINA
807 WEST KING ST
ELIZABETHTOWN, NC, 28337

OCCUPANT
PRESBYTERY OF COASTAL CAROLINA
807 WEST KING ST
ELIZABETHTOWN, NC, 28337

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
11/22/2010	Routine	Re-issued	48 - Martin	BLADEN

9

VIOLATIONS

2.27.3.1 Put the Phase I fire service feature in proper working order.

Items must be corrected by: 11/22/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: DE SCOTT

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
PRESBYTERY OF COASTAL CAROLINA
807 WEST KING ST
ELIZABETHTOWN, NC, 28337