



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10334-48-4393
State Number
12252

EQUIPMENT INSPECTED

State Number: 12252	Type of Unit: Passenger	Floor to Floor: 1 to -
Capacity: 4000	Manuf: SOUTHERN	Speed: 100
Landings: 5	Installed: 11/03/1987	Rope Size: 5/8
Volts: 480	Complied: 06/12/2006	Entrances: 1
OWNER	OCCUPANT	
CAPITAL POWER CORP.	CAPITAL POWER CORP.	
PO BOX 10836	1281 POWERHOUSE DR.	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 11/30/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2	Perform the annual no load safety test
8.6.4.9	Clean the car top of all debris.
8.6.4.7.1	Clean the elevator pit.
N/A	REPLACE SPIRATOR CABLE ON 1ST FL SHAFT DOOR

Items must be corrected by: 12/30/2010

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DAVID

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAPITAL POWER CORP.
PO BOX 10836
SOUTHPORT, NC, 28461