



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10335-48-5638**  
State Number  
**20696**

EQUIPMENT INSPECTED

State Number: <b>20696</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 07/22/2002	Rope Size: 0
Volts: 208	Complied: 07/24/1992	Entrances: 1
OWNER	OCCUPANT	
CLEAR WATER PLACE	CLEAR WATER PLACE	
1620 GOLEY HEWETT RD.	1620 GOLEY HEWETT RD.	
BOLIVIA, NC, 28422	BOLIVIA, NC, 28422	

INSPECTION INFORMATION

Inspection Date 12/01/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CLEAR WATER PLACE  
1620 GOLEY HEWETT RD.  
BOLIVIA, NC, 28422