



INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10347-33-382
State Number
10065

EQUIPMENT INSPECTED

State Number: **10065** Type of Unit: Passenger Floor to Floor: M to 14
Capacity: 3500 Manuf: WESTINGHOUSE Speed: 450
Landings: 13 Installed: 03/05/1982 Rope Size: 5/8
Volts: 480 Complied: 04/29/1982 Entrances: 1

OWNER
HINES CHARLOTTE PLAZA LP
201 S COLLEGE ST SUITE 2270
CHARLOTTE, NC, 28244

OCCUPANT
CHARLOTTE PLAZA
201 S. COLLEGE ST.
CHARLOTTE, NC, 28244

INSPECTION INFORMATION

Inspection Date 12/13/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 33 - Dye	County MECKLENBURG	60 D
-------------------------------	----------------------------	---------------------------------	-----------------------	-----------------------	------

VIOLATIONS

None at this time

Elevator Name: ELEVATOR #2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jesse Amundson 704 376-4186

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372
An invoice will be mailed to: HINES CHARLOTTE PLAZA LP
201 S COLLEGE ST SUITE 2270
CHARLOTTE, NC, 28244