



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10348-48-3675
State Number
H1689

EQUIPMENT INSPECTED

State Number: H1689	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: ACCESS	Speed: 12
Landings: 2	Installed: 03/13/2006	Rope Size: 0
Volts: 115	Complied: 03/20/2006	Entrances: 2
OWNER	OCCUPANT	
OCEAN RIDGE BEACH CLUB	OCEAN RIDGE ROAD	
8 E MAIN STREET	8 E MAIN STREET	
SUNSET BEACH, NC, 28462	SUNSET BEACH, NC, 28462	

INSPECTION INFORMATION

Inspection Date 12/14/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Unavailable

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

OCEAN RIDGE BEACH CLUB
8 E MAIN STREET
SUNSET BEACH, NC, 28462