N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10348-48-5543
State Number
17610

EQUIPMENT INSPECTED

State Number: **17610**
Capacity: 4500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 06/30/1998
Complied: 04/06/2000

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 2

OWNER
SEA TRAIL CORP
211 CLUBHOUSE RD
SUNSET BEACH, NC, 28468

OCCUPANT
JONES / BRYD CLUBHOUSE
211 CLUBHOUSE RD
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
12/14/2010	Routine	Re-issued	48 - Martin	BRUNSWICK	10

VIOLATIONS

8.6.4.8.4 Access doors shall be kept closed and locked. MR door to close & lock on it's own.

Items must be corrected by: 01/03/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Robbie

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SEA TRAIL CORP
211 CLUBHOUSE RD
SUNSET BEACH, NC, 28468