N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
10349-48-3287
State Number
23829

EQUIPMENT INSPECTED

State Number: **23829**
Capacity: 2100
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 03/30/2006
Complied: 03/30/2006

Floor to Floor: 1 to 2
Speed: 95
Rope Size:
Entrances: 1

OWNER
RIVERS EDGE GOLF CLUB
350 CHERRY HILL LANE
SHALLOTTE, NC, 28470

OCCUPANT
RIVERS EDGE CLUBHOUSE
350 CHERRY HILL LANE
SHALLOTTE, NC, 28470

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
12/15/2010	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
RIVERS EDGE GOLF CLUB
350 CHERRY HILL LANE
SHALLOTTE, NC, 28470