



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**10356-36-2859**  
State Number  
**18190**

EQUIPMENT INSPECTED

State Number: <b>18190</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 135
Landings: 3	Installed: 01/25/1999	Rope Size:
Volts: 480	Complied: 01/25/1999	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON UNIV / DUKE BLDG	
803 EAST HAGGARD STREET	302 E HAGGARD ST	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 12/22/2010	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob Willis 336.278.2000

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY  
803 EAST HAGGARD STREET  
ELON, NC, 27244