



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11004-36-2189
State Number
27131

EQUIPMENT INSPECTED

State Number: 27131	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 110
Landings: 3	Installed: 08/03/2009	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	ELON UNIVERSITY POWELL HALL RENOV	
803 W HAGGARD AVENUE	803 W HAGGARD AVENUE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 01/04/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob 336.278.2000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
803 W HAGGARD AVENUE
ELON, NC, 27244