



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11012-36-2043**  
State Number  
**14999**

EQUIPMENT INSPECTED

State Number: <b>14999</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: WEBSTER	Speed: 110
Landings: 2	Installed: 03/31/1993	Rope Size:
Volts: 208	Complied: 03/31/1993	Entrances: 1
OWNER	OCCUPANT	
LAB CORP	LAB CORP "CHURCH HILL BDLG"	
348 S MAIN ST	338 N MAIN ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 01/12/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LORIE FLINCHUM 33-436-7777

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAB CORP  
348 S MAIN ST  
BURLINGTON, NC, 27215