



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11021-17-2721
State Number
9951

EQUIPMENT INSPECTED

| | | |
|---------------------------|-------------------------|------------------------|
| State Number: 9951 | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2000 | Manuf: SOUTHERN | Speed: 125 |
| Landings: 2 | Installed: 06/23/1981 | Rope Size: |
| Volts: 230 | Complied: 06/23/1981 | Entrances: 1 |

OWNER

AB TECH COLLEGE /BIRCH BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801

OCCUPANT

AB TECH COLLEGE /BIRCH BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

| | | | | | |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|
| Inspection Date 01/21/2011 | Type Inspection Routine | Certificate Status Re-issued | Inspector 17 - White | County BUNCOMBE | 11 A |
|-------------------------------|----------------------------|---------------------------------|-------------------------|--------------------|------|

VIOLATIONS

8.6.4 Cover car interior lights

Items must be corrected by: 02/20/2011

Elevator Name: birch

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Marty 828-254-1921

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AB TECH COLLEGE /BIRCH BLDG
340 VICTORIA RD
ASHEVILLE, NC, 28801