



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11025-16-2234
State Number
9865

EQUIPMENT INSPECTED

State Number: 9865	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: SOUTHERN	Speed: 125
Landings: 4	Installed: 08/17/1981	Rope Size: 0
Volts: 208	Complied: 05/12/2003	Entrances: 1
OWNER WASHINGTON HOUSING AUTHORITY PO BOX 1046 WASHINGTON, NC, 27889		OCCUPANT EAST HAVEN 407 E. THIRD STREET WASHINGTON, NC, 27889

INSPECTION INFORMATION

Inspection Date 01/25/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.25.2 Put the directional limit device in proper working order. Down normal won't stop car before in engages spring buffer
8.6.4.13.1[k] Properly maintain door closers, where required. 1st floor door won't close properly

Items must be corrected by: 02/24/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Carroll Maintenance Super

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WASHINGTON HOUSING AUTHORITY
PO BOX 1046
WASHINGTON, NC, 27889