



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11027-12-1390
State Number
16142

EQUIPMENT INSPECTED

| | | |
|----------------------------|-------------------------|------------------------|
| State Number: 16142 | Type of Unit: Passenger | Floor to Floor: 1 to 4 |
| Capacity: 8000 | Manuf: THYSSEN KRUPP | Speed: 100 |
| Landings: 4 | Installed: 03/28/1996 | Rope Size: 5/8 |
| Volts: 480 | Complied: 04/10/1996 | Entrances: 1 |

OWNER

STAR PET
801 PINEVIEW RD
ASHEBORO, NC, 27203

OCCUPANT

STAR PET
801 PINEVIEW RD
ASHEBORO, NC, 27203

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|--------------------|
| Inspection Date 01/27/2011 | Type Inspection Routine | Certificate Status Re-issued | Inspector 12 - Essick | County RANDOLPH |
|-------------------------------|----------------------------|---------------------------------|--------------------------|--------------------|

76

VIOLATIONS

- 2.27 Missing firemans service instructions at bottom floor lobby
- 2.27 Missing Braille on car call station
- 2.27 Provide "In Case Of Fire Use Stairs" signs at all floor lobbys

Items must be corrected by: 02/26/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: John Layton, Maint, 336 672 0101x305

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

STAR PET
801 PINEVIEW RD
ASHEBORO, NC, 27203