



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11027-36-005
State Number
2860

EQUIPMENT INSPECTED

State Number: 2860	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4000	Manuf: MONARCH	Speed: 60
Landings: 2	Installed: 10/01/1956	Rope Size:
Volts: 440	Complied: 11/28/1956	Entrances: 1
OWNER	OCCUPANT	
AMI	AMI	
2609 TUCKER ST	204 N GRA-HOPEDALE RD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 01/27/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jay 336-213-4457

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AMI
2609 TUCKER ST
BURLINGTON, NC, 27215