



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11034-24-0965
State Number
20804

EQUIPMENT INSPECTED

State Number: 20804	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCHINDLER	Speed: 150
Landings: 3	Installed: 03/21/2002	Rope Size:
Volts: 208	Complied: 05/02/2002	Entrances: 1
OWNER	OCCUPANT	
EQUITY INNS	SPRINGHILL SUITES HOTEL	
7700 WOLF RIVER BLVD	2 BUCKSTONE PLACE	
GERMANTOWN, TN, 38138	ASHEVILLE, NC, 28805	

INSPECTION INFORMATION

Inspection Date 02/03/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.1.6	General Maintenance : Investigate door operator noise.
2.27.7.1	Provide Phase I fire service instructions at the recall landing.

Items must be corrected by: 03/05/2011

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jim Zellers /828-253-4666

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

EQUITY INNS
7700 WOLF RIVER BLVD
GERMANTOWN, TN, 38138