



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11042-36-3297
State Number
25045

EQUIPMENT INSPECTED

State Number: 25045	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: TOCE	Speed: 100
Landings: 2	Installed: 11/14/2007	Rope Size:
Volts: 200	Complied:	Entrances: 2
OWNER	OCCUPANT	
THE CITY OF BURLINGTON	THE OLD FIRST UNION BUILDING	
425 SOUTH LEXINTON STREET	244 W DAVIS STREET	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/11/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: OFFICE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE CITY OF BURLINGTON
425 SOUTH LEXINTON STREET
BURLINGTON, NC, 27215