



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11052-48-1124
State Number
23591

EQUIPMENT INSPECTED

State Number: 23591	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 03/08/2006	Rope Size: 0
Volts: 240	Complied: 03/08/2006	Entrances: 1

OWNER

LAWRENCE COASTAL REAL ESTATE
5003 O'QUINN BLVD.
SOUTHPORT, NC, 28461

OCCUPANT

SOUTHPORT CONDOS BLDG #5
614 W. BROWN STREET
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date 02/21/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.7.5.1	Put the machine room lights in working order.
8.6.4.7.1	Clean the elevator pit.

Items must be corrected by: 03/13/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAWRENCE COASTAL REAL ESTATE
5003 O'QUINN BLVD.
SOUTHPORT, NC, 28461