



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11052-48-5959**  
State Number  
**21546**

EQUIPMENT INSPECTED

State Number: <b>21546</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 07/02/2003	Rope Size: 0
Volts: 240	Complied: 07/11/2003	Entrances: 1

OWNER

LAWRENCE COASTAL REAL ESTATE  
5003 O'QUINN BLVD.  
SOUTHPORT, NC, 28461

OCCUPANT

SOUTHPORT CONDOS BLDG.#3  
610 W. BROWN STREET  
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date 02/21/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 03/13/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAWRENCE COASTAL REAL ESTATE  
5003 O'QUINN BLVD.  
SOUTHPORT, NC, 28461