



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11060-7-5722
State Number
24076

EQUIPMENT INSPECTED

State Number: 24076	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 08/01/2006	Rope Size: 0
Volts: 208	Complied: 08/02/2006	Entrances: 1
OWNER	OCCUPANT	
BETHLEHEM BAPTIST CHURCH	BETHLEHEM BAPTIST CHURCH	
7500 N.C. HWY 127	7500 N.C. HWY 127	
BETHLEHEM, NC, 28681	BETHLEHEM, NC, 28681	

INSPECTION INFORMATION

Inspection Date 03/01/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 7 - Hoffman	County ALEXANDER
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

2

VIOLATIONS

NONE

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bethlehem Baptist Ch. 828-495-7520

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BETHLEHEM BAPTIST CHURCH
7500 N.C. HWY 127
BETHLEHEM, NC, 28681