

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 11061-24-405 State Number 16683

EQUIPMENT INSPECTED					
State Number: 16683 Capacity: 2000	Manuf: KONE	Type of Unit: Passenger Manuf: KONE		Floor to Floor: 1 to 3 Speed: 125	
Landings: 3 Installed: 09/16/1997 Volts: 208 Complied: 10/31/1997			Rope Size:		
OWNER 32 BROADWAY CONDO ASSOC			OCCUPANT JENKINS BLDG		
32 BROADWAY ST UNIT 100	,	32 BROADWAY ST			
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801				
	IN	SPECTION INFORMATION			
Inspection Date 03/02/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
		VIOLATIONS			
8.6.1.6.5 Provide a tested up to or 2.27.1.1.2 Put the in car emergence	ey light and alarm in working or date class ABC fire extinguisher ey telephone in proper working for the annual fire alarm initiat	r in machinery space. Last date order. LAST NOTICE !!!!!!!!!	4 / 09. !!!!!!!!!!!!!!!!		
Items must be corrected by: 04/0	1/2011	Eleva	ator Name: ELEVATOR #	<i>‡</i> 1	
Notify the Elevator Bureau in writing complainace with current codes.	on Corrected Violations Form	when the following corrections	s have been made in order	to bring your equipment in	ıto
Violations pointed out to: John Ewin	_				
	make changes to the invoice m	ailing address please call: 919-	733-0372		
THIS IS NOT AN INVOICE An	invoice will be mailed to:	32 BROADWAY CON 32 BROADWAY ST U ASHEVILLE, NC, 288	JNIT 100		