



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11068-7-4349
State Number
488

EQUIPMENT INSPECTED

State Number: 488	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: MONARCH	Speed: 75
Landings: 3	Installed: 09/05/1945	Rope Size: 1/2
Volts: 220	Complied: 09/05/1945	Entrances: 1
OWNER	OCCUPANT	
LINDLE & ASSOCIATES	LINDLE & ASSOCIATES	
23 EAST MAIN AVENUE	23 EAST MAIN AVENUE	
TAYLORSVILLE, NC, 28681	TAYLORSVILLE, NC, 28681	

INSPECTION INFORMATION

Inspection Date 03/09/2011	Type Inspection Not Inspected	Certificate Status Not Issued	Inspector 7 - Hoffman	County ALEXANDER
-------------------------------	----------------------------------	----------------------------------	--------------------------	---------------------

2

VIOLATIONS

BUILDING EMPTY INSPECTION NOTICE POSTED

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LINDLE & ASSOC

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LINDLE & ASSOCIATES
23 EAST MAIN AVENUE
TAYLORSVILLE, NC, 28681