N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11080-36-1826
State Number
1037

EQUIPMENT INSPECTED

State Number: **1037**	Type of Unit: Freight	Floor to Floor: B to 1
Capacity: 3000	Manuf: WESTBROOK	Speed: 60
Landings: 2	Installed: 02/17/1948	Rope Size: 1/2
Volts: 220	Complied: 04/04/1991	Entrances: 2

OWNER
GRAHAM DYEING & FINISHING
110 N BROAD ST
BURLINGTON, NC, 27215

OCCUPANT
GRAHAM DYEING & FINISHING
110 N BROAD ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/21/2011	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: THOMAS ALLEN 336-228-9981 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
GRAHAM DYEING & FINISHING
110 N BROAD ST
BURLINGTON, NC, 27215