



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11082-52-4086**  
State Number  
**8022**

EQUIPMENT INSPECTED

|                           |                         |                        |
|---------------------------|-------------------------|------------------------|
| State Number: <b>8022</b> | Type of Unit: Passenger | Floor to Floor: 1 to 2 |
| Capacity: 2000            | Manuf: THYSSEN KRUPP    | Speed: 125             |
| Landings: 2               | Installed: 08/06/1975   | Rope Size: 0           |
| Volts: 220                | Complied: 08/06/1975    | Entrances: 1           |
| OWNER                     | OCCUPANT                |                        |
| AVERY COUNTY              | AVERY COUNTY COURTHOUSE |                        |
| P.O. BOX 640              | 200 MONTEZUMA STREET    |                        |
| NEWLAND, NC, 28657        | NEWLAND, NC, 28657      |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                           |                 |
|-------------------------------|----------------------------|---------------------------------|---------------------------|-----------------|
| Inspection Date<br>03/23/2011 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>52 - Sosebee | County<br>AVERY |
|-------------------------------|----------------------------|---------------------------------|---------------------------|-----------------|

6

VIOLATIONS

8.11.3.2.1 Provide the annual relief valve and system pressure test.

Items must be corrected by: 04/22/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Avery County 828-387-0072

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY  
P.O. BOX 640  
NEWLAND, NC, 28657