

Violations pointed out to: Avery County 828-733-6006

An invoice will be mailed to:

THIS IS NOT AN

INVOICE

N C Department of Labor Elevator Bureau 1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in any correspondence relating to your equipment www.nclabor.com/elevator.htm 919-707-7927 Report Number 11084-52-2863 State Number 9018

6

EQUIPMENT INSPECTED						
State Number: 9018 Capacity: 2100		Type of Unit: Passenger Manuf: THYSSEN KRUPP		Floor to Floor: 1 to 3 Speed: 125		
Landings: 3 Volts: 220		Installed: 11/02/1978 Complied: 11/17/1978		Rope Size: 0 Entrances: 1		
				Entrances: 1		
OWNER		OCCUPANT		Y0.0Y		
AVERY COUNTY SCHOOLS		AVERY COUNT MIDDLE SCH				
P.O. BOX 1360		102 OLD MONTEZUMA ROAI		D		
NEWLAND, NC, 28657		NEWLAND, NC, 28657				
		INS	PECTION INFORMATION			
Inspection Date 03/25/2011		Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY	
			VIOLATIONS			
5.1.21.1	Put the in car	Put the in car alarm bell in working order.				
2.7.5.1						
To	. 11 04/24/	2011				
	corrected by: 04/24/					
Notify the Elevator complainace with or		on Corrected Violations Form w	when the following corrections have be	een made in order to bring your	equipment into	

P.O. BOX 1360 NEWLAND, NC, 28657

AVERY COUNTY SCHOOLS

To make changes to the invoice mailing address please call: 919-733-0372

Inspector ___