



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11084-52-3045
State Number
16223

EQUIPMENT INSPECTED

State Number: 16223	Type of Unit: Passenger	Floor to Floor: LL to UL
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 3	Installed: 11/14/1996	Rope Size: 0
Volts: 460	Complied: 11/25/1996	Entrances: 1
OWNER	OCCUPANT	
AVERY COUNTY SCHOOLS	FREEDOM TRAIL ELEMENTARY	
P.O. BOX 1360	6230 HWY19 EAST	
NEWLAND, NC, 28657	NEWLAND, NC, 28657	

INSPECTION INFORMATION

Inspection Date 03/25/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order. **3rd notice.**
8.6	General maintenance, tighten handrails in car.

Items must be corrected by: 04/24/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Avery County 828-733-6006

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY SCHOOLS
P.O. BOX 1360
NEWLAND, NC, 28657