



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11088-52-1873**  
State Number  
**H1711**

EQUIPMENT INSPECTED

State Number: <b>H1711</b>	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: NATL W-O-V	Speed: 20
Landings: 2	Installed: 07/05/2006	Rope Size: 0
Volts: 115	Complied:	Entrances: 1
OWNER	OCCUPANT	
GRANDFATHER HIGHLAND CENTER	GRANDFATHER HIGHLAND GAMES	
P.O.BOX 1095	4210 MITCHEL AVENUE	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 03/29/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 52 - Sosebee	County AVERY
-------------------------------	----------------------------	---------------------------------	---------------------------	-----------------

6

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.11.2.3.1	Provide the annual no load test.

Items must be corrected by: 04/28/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: G.H.G. 828-733-1333

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRANDFATHER HIGHLAND CENTER  
P.O.BOX 1095  
LINVILLE, NC, 28646