



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11089-36-2417
State Number
6947

EQUIPMENT INSPECTED

State Number: 6947	Type of Unit: Freight	Floor to Floor: B to 1
Capacity: 3000	Manuf: SOUTHERN	Speed: 65
Landings: 2	Installed: 03/15/1971	Rope Size:
Volts: 220	Complied: 03/15/1971	Entrances: 1
OWNER	OCCUPANT	
SIMS POTTERY	SIMS POTTERY	
563 W MOORE ST	563 W MOORE ST	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 03/30/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DOUG SEARS 336-228-1518

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SIMS POTTERY
563 W MOORE ST
GRAHAM, NC, 27253