



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11094-17-3080**  
State Number  
**10310**

EQUIPMENT INSPECTED

State Number: <b>10310</b>	Type of Unit: Passenger	Floor to Floor: G to 2
Capacity: 2500	Manuf: ASHEVILLE	Speed: 100
Landings: 3	Installed: 11/01/1982	Rope Size:
Volts: 208	Complied: 11/01/1982	Entrances: 1
OWNER	OCCUPANT	
30 CHOCTAW OFFICE BLDG	30 CHOCTAW OFFICE BLDG	
30 CHOCTAW ST	30 CHOCTAW ST	
ASHEVILLE, NC, 28801	ASHEVILLE, NC, 28801	

INSPECTION INFORMATION

Inspection Date 04/04/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

8.6.4	Cover or guard car interior lighting tubes.
8.6.4	Cover or guard car interior lighting tubes.

Items must be corrected by: 05/04/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: office 828-254-1963

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

30 CHOCTAW OFFICE BLDG  
30 CHOCTAW ST  
ASHEVILLE, NC, 28801