



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11095-16-367
State Number
4769

EQUIPMENT INSPECTED

State Number: 4769	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 2700	Manuf: WESTBROOK	Speed: 75
Landings: 3	Installed: 09/26/1962	Rope Size: 1/2
Volts: 220	Complied: 09/26/1962	Entrances: 1
OWNER	OCCUPANT	
JAMES FORTESCUE	STAR CRAFT	
248 NANCE LAND	444 STEWART PKWY	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 04/05/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Jim Fortescue

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

JAMES FORTESCUE
248 NANCE LAND
WASHINGTON, NC, 27889