



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11095-36-3674
State Number
23117

EQUIPMENT INSPECTED

State Number: 23117	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: SCHINDLER	Speed: 125
Landings: 3	Installed: 11/28/2005	Rope Size: .
Volts: 208	Complied: 12/27/2005	Entrances: 1
OWNER	OCCUPANT	
HAROLD K JORDAN	RIVER MILL	
1806 CLASIC RD	1613 BETHLEHAM CHRUCH RD	
APEX, NC, 27532	SAXAPAHAW, NC, 27340	

INSPECTION INFORMATION

Inspection Date 04/05/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

NONE FOUND

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complianace with current codes.

Violations pointed out to: LEE MAN 336-376-3122

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

HAROLD K JORDAN
1806 CLASIC RD
APEX, NC, 27532