N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11108-36-2876
State Number
5813

EQUIPMENT INSPECTED

State Number: **5813**
Capacity: 8000
Landings: 2
Volts: 550

Type of Unit: Freight
Manuf: WESTBROOK
Installed: 04/08/1968
Complied: 10/11/1991

Floor to Floor: 1 to 2
Speed: 100
Rope Size:
Entrances: 1

OWNER
ELITE WAREHOUSE LLC
3000 RDU CENTER DRIVE STE 102
MORRISVILLE, NC, 27560

OCCUPANT
ELITE WAREHOUSE LLC
300 PARKER ST
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
04/18/2011	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

8.6.4.13.1 Take steps to maintain and provide proper operation of the door system , escutcheons, up-thrusts, door rollers, etc. (all landing, car door, gate components) (SECOND NOTICE)!!!

8.6.1.2.1 Provide a written maintenance program.

8.11.2.2.2 Perform an annual no load safety test and provide proper tags. (SECOND NOTICE)!!

8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 04/28/2011

Elevator Name: saurabh wag

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: vincent smith 919-433-6224

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ELITE WAREHOUSE LLC
3000 RDU CENTER DRIVE STE 102
MORRISVILLE, NC, 27560