



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11108-36-3158
State Number
4065

EQUIPMENT INSPECTED

State Number: 4065	Type of Unit: Freight	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: WESTBROOK	Speed: 50
Landings: 3	Installed: 05/13/1960	Rope Size: 5/8
Volts: 550	Complied: 10/02/1996	Entrances: 1
OWNER		OCCUPANT
ELITE WAREHOUS LCC		ELITE WAREHOUSE LLC
3000 RDU CENTER DRIVE STE 102		300 E PARKER ST
MORRISVILLE, NC, 27560		GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 04/18/2011	Type Inspection Condemned	Certificate Status Not Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	------------------------------	----------------------------------	---------------------------	--------------------

1

VIOLATIONS

A-17-1 TAKE STEPS TO PROPERLY LAND ELEVATOR. THIS UNIT HAS BEEN DORMANT FOR MORE THAN 12 MONTHS

Items must be corrected by: 05/18/2011

Elevator Name: BUILDING # A

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: VINCENT SMITH 919-433-6224

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELITE WAREHOUS LCC
3000 RDU CENTER DRIVE STE 102
MORRISVILLE, NC, 27560