



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11108-36-4382
State Number
5814

EQUIPMENT INSPECTED

State Number: 5814	Type of Unit: Freight	Floor to Floor: B to 2
Capacity: 8000	Manuf: WESTBROOK	Speed: 100
Landings: 3	Installed: 02/28/1968	Rope Size:
Volts: 550	Complied: 05/24/2005	Entrances: 1
OWNER		OCCUPANT
ELITE WAREHOUSE LLC		ELITE WAREHOUSE LLC
3000 RDU CENTER DRIVE STE 102		300 E PARKER ST
MORRISVILLE, NC, 27560		GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 04/18/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
2.14.7.1.3	Put the in car emergency light in working order.
2.14.4.7	Repair the damaged car gate. (SECOND NOTICE)!!!!
8.6.1.2.1	Provide a written maintenance program.
8.11.3.2.1	Perform the annual relief valve test (SECOND NOTICE)!!!

Items must be corrected by: 04/28/2011

Elevator Name: BUILDING # A

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: vincent smith 919-433-6224

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELITE WAREHOUSE LLC
3000 RDU CENTER DRIVE STE 102
MORRISVILLE, NC, 27560