



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11108-36-5752
State Number
112

EQUIPMENT INSPECTED

| | | |
|-------------------------------|-----------------------|------------------------|
| State Number: 112 | Type of Unit: Freight | Floor to Floor: B to 3 |
| Capacity: 2000 | Manuf: MONARCH | Speed: 60 |
| Landings: 4 | Installed: 01/10/1941 | Rope Size: 1/2 |
| Volts: 550 | Complied: 10/31/1958 | Entrances: 1 |
| OWNER | OCCUPANT | |
| ELITE WAREHOUSE LLC | ELITE WAREHOUSE LLC | |
| 3000 RDU CENTER DRIVE STE 102 | 300 E PARKER ST | |
| MORRISVILLE, NC, 27560 | GRAHAM, NC, 28253 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|------------------------------|----------------------------------|---------------------------|--------------------|
| Inspection Date 04/18/2011 | Type Inspection Condemned | Certificate Status Not Issued | Inspector 36 - Kirkman | County ALAMANCE |
|-------------------------------|------------------------------|----------------------------------|---------------------------|--------------------|

1

VIOLATIONS

A17-1 TAKE STEPS TO PROPERLY LAND ELEVATOR. THIS UNIT HAS BEEN DORMANT FOR MORE THAN 12 MONTHS!!

Items must be corrected by: 05/18/2011

Elevator Name: BUILDING B

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: VINCENT SMITH 919-433-6224

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELITE WAREHOUSE LLC
3000 RDU CENTER DRIVE STE 102
MORRISVILLE, NC, 27560