



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11122-16-5731**  
State Number  
**23874**

EQUIPMENT INSPECTED

State Number: <b>23874</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 80
Landings: 2	Installed: 07/17/2006	Rope Size: 0
Volts: 208	Complied: 07/20/2006	Entrances: 1
OWNER	OCCUPANT	
BAY LEAF PLANTATION SENIOR	BAY LEAF PLANTATION SENIOR	
1120 COWELL FARM ROAD	1120 COWELL FARM ROAD	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 05/02/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

n/a No violations found

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Darcy Vyner

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BAY LEAF PLANTATION SENIOR  
1120 COWELL FARM ROAD  
WASHINGTON, NC, 27889