



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11125-36-2578
State Number
27754

EQUIPMENT INSPECTED

State Number: 27754	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 70
Landings: 2	Installed:	Rope Size:
Volts: 208	Complied:	Entrances: 2
OWNER	OCCUPANT	
RIVERMILL ACADEMY	RIVERMILL ACADEMY	
1242 S MAIN STREET	1242 S MAIN STREET	
GRAHAM, NC, 27253	GRAHAM, NC, 27253	

INSPECTION INFORMATION

Inspection Date 05/05/2011	Type Inspection New	Certificate Status Not Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	------------------------	----------------------------------	---------------------------	--------------------

1

VIOLATIONS

Place fire alarm in proper working order

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: phillip burnett

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RIVERMILL ACADEMY
1242 S MAIN STREET
GRAHAM, NC, 27253