N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11125-48-2291
State Number
23516

EQUIPMENT INSPECTED

State Number: **23516**
Capacity: 2100
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 02/22/2006
Complied: 02/22/2006

Floor to Floor: 1 to 3
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
COMMUNITY AASOCIATION MGMT.
P.O. BOX 8126
0CEAN ISLE BEACH, NC, 28469

OCCUPANT
VILLAS ON OSPREY RIDGE
174 CLUB HOUSE RD
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/05/2011	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
2.27.1.1.2	Put the in car emergency telephone in proper working order.

Items must be corrected by: 05/25/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
COMMUNITY AASOCIATION MGMT.
P.O. BOX 8126
0CEAN ISLE BEACH, NC, 28469