N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
**11125-48-5937**
State Number
**23519**

EQUIPMENT INSPECTED

| | | |
|---|---|---|
| State Number: **23519** | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 2100 | Manuf: OTIS | Speed: 100 |
| Landings: 3 | Installed: 02/22/2006 | Rope Size: 0 |
| Volts: 208 | Complied: 02/22/2006 | Entrances: 1 |

OWNER
COMMUNITY ASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469

OCCUPANT
VILLAS ON OSPREY RIDGE
172 CLUB HOUSE RD
SUNSET BEACH, NC, 28468

INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County | |
|---|---|---|---|---|---|
| 05/05/2011 | Routine | Re-issued | 48 - Martin | BRUNSWICK | 10 |

VIOLATIONS

| | |
|---|---|
| 8.6.4.7.1 | Clean the elevator pit. |
| 2.27.1.1.2 | Put the in car emergency telephone in proper working order. |

Items must be corrected by: 05/25/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
COMMUNITY ASSOCIATION MGMT.
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469