



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11133-24-234**  
State Number  
**10294**

EQUIPMENT INSPECTED

State Number: <b>10294</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: GENERAL	Speed: 100
Landings: 4	Installed: 07/09/1982	Rope Size:
Volts: 208	Complied: 07/09/1982	Entrances: 1

OWNER

72 PATTON ASSOCIATES  
72 PATTON AVENUE  
ASHEVILLE, NC, 28801

OCCUPANT

72 PATTON ASSOCIATES  
72 PATTON AVENUE  
ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 05/13/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 24 - Moore	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------	------

VIOLATIONS

2.14.7.4 Protect the car lights from accidental contact. End caps missing on tube over C.O.P.. Replace endcaps.

Items must be corrected by: 06/12/2011

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Linda English / 828-252-7381

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

72 PATTON ASSOCIATES  
72 PATTON AVENUE  
ASHEVILLE, NC, 28801