N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
**11137-48-4442**
State Number
**25786**

## EQUIPMENT INSPECTED

| | | |
|---|---|---|
| State Number: **25786** | Type of Unit: Passenger | Floor to Floor: 1 to 3 |
| Capacity: 4000 | Manuf: SCHINDLER | Speed: 150 |
| Landings: 3 | Installed: 08/06/2008 | Rope Size: |
| Volts: 480 | Complied: 08/06/2008 | Entrances: 2 |

OWNER
BRUNSWICK CO COURTHOUSE OPERATION SERVIC
P.O. BOX 249
BOLIVIA, NC, 28422

OCCUPANT
BRUNSWICK COUNTY ADMIN BLDG
30 GOVERNMENT CENTER DRIVE
BOLIVIA, NC, 28422

## INSPECTION INFORMATION

| Inspection Date | Type Inspection | Certificate Status | Inspector | County |
|---|---|---|---|---|
| 05/17/2011 | Routine | Re-issued | 48 - Martin | BRUNSWICK |

10

## VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 05/27/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: KEVIN

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
BRUNSWICK CO COURTHOUSE OPERATION SERVIC
P.O. BOX 249
BOLIVIA, NC, 28422