



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**11144-36-2069**  
State Number  
**19724**

EQUIPMENT INSPECTED

State Number: <b>19724</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: MIM ELE	Speed: 100
Landings: 3	Installed: 03/14/2001	Rope Size:
Volts: 208	Complied: 03/27/2001	Entrances: 1
OWNER		OCCUPANT
RBC BANK (USA) ATTN: BRITTANY HORNER		MONTWHITE BLDG
500 WEST MORGAN STREET		200B N MAIN ST
DURHAM, NC, 27701		GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 05/24/2011	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

8.6.4.8.1	Clean the elevator machine room.
8.6.4.9	Clean the car top of all debris.
8.6.1.2.1	Provide a written maintenance program.
2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.4.7.1	Clean the elevator pit.
8.11.2.3	Perform a 5 year full load safety test
8.6	LUBE RAILS AND COMPONENTS

Items must be corrected by: 06/23/2011

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JASON 919-687-3506

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

RBC BANK (USA) ATTN: BRITTANY HORNER  
| 500 WEST MORGAN STREET  
DURHAM, NC, 27701