N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
11153-48-5341
State Number
21779

EQUIPMENT INSPECTED

State Number: **21779**
Capacity: 4500
Landings: 2
Volts: 480

Type of Unit: Passenger
Manuf: OTIS
Installed: 05/14/2004
Complied: 05/14/2004

Floor to Floor: 1 to 2
Speed: 100
Rope Size: .
Entrances: 1

OWNER
DOSHER MEMORIAL HOSPITAL
924 N HOWE ST
SOUTHPORT, NC, 28461

OCCUPANT
DOSHER MEMORIAL HOSPITAL
924 N HOWE ST
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/02/2011	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

n/a No violations found

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: DANIEL

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
DOSHER MEMORIAL HOSPITAL
924 N HOWE ST
SOUTHPORT, NC, 28461